

Mfpa Leipzig GmbH

Testing, Inspection and Certification Authority for
Construction Products and Construction Types

Leipzig Institute for Materials Research and Testing
Business Division III - Structural Fire Protection

Dipl.-Ing. Sebastian Hauswaldt

Work Group 3.2 - Fire Behaviour of Building Components and
special Constructions

Dipl.-Wirtsch.-Ing. S. Kramer

Tel.: +49 (0) 341 - 6582-194

kramer@mfpa-leipzig.de

Classification Report No. KB 3.2/14-013-2

04 December 2014

No. Copy 1

Translation of the original German document KB 3.2/14-013-2

Subject matter:

Classification of a load-bearing, space-enclosing and thermally-insulating MHM wall element with a lining of 9.5 mm thick gypsum plasterboards (GP boards) on the side facing away from the fire and 15 mm thick plasterboard fire bats (PBF bats) on the side facing the fire with a one-sided fire load acc. to DIN EN 13501-2: 2010-2*

Client:

Massiv-Holz-Mauer Entwicklungs GmbH

Auf der Geigerhalde 41
D – 87459 Pfronten-Weißbach

Person in charge:

Dipl.-Wirtsch.-Ing. S. Kramer

The classification report is not a type approval or product certification. It does not replace any building authority certificate that may be necessary according to German building laws (state building code) and is only valid in conjunction with the corresponding test report.

This document consists of 5 pages and may not be used or reproduced in extracts.

This document may only be reproduced in its unabbreviated form. All publication, even in excerpts, requires the prior written permission of Mfpa Leipzig GmbH. The legal binding form is the written form in German with the original signatures and original stamp of the authorized signatory / signatories.

General terms and conditions of Mfpa Leipzig GmbH are valid.



Test laboratory accredited by DAkkS GmbH according to DIN EN ISO/IEC 17025. The accreditation only applies to the test methods listed in the certificate (in this document marked with *) which can be seen on www.mfpa-leipzig.de

Notified testing laboratories, inspection bodies and certification bodies recognized according to the Construction Products Law (NB 800) and the State Building Code (SAC 02).

Gesellschaft für Materialforschung und Prüfungsanstalt für das Bauwesen Leipzig mbH (Mfpa Leipzig GmbH)

Head Office: Hans-Weigel-Str. 2b – 04319 Leipzig/Germany
Managing Director: Prof. Dr.-Ing. Frank Dehn
Comm. Register: Local Court Leipzig HRB 17719
VAT-ID: DE 813200649
Tel.: +49 (0) 341 - 6582-0
Fax: +49 (0) 341 - 6582-135

1 Introduction

This classification report defines the classification assigned to the load-bearing, space-enclosing and thermally-insulating MHM wall element in accordance with the procedure specified in DIN EN 13501-2: 2010-2.

2 Details of the classified product

2.1 General

The MHM wall element with a lining of 9.5 mm thick gypsum plasterboards (GP boards) on the side facing away from the fire and 15 mm thick plasterboard fire bats (PBF bats) on the side facing the fire is defined as a load-bearing, space enclosing, thermally-insulating wall structure that is classified in accordance with DIN EN 1365-1 in conjunction with DIN EN 13501-2 section 7.3.2. Its function is to resist fire corresponding to the characteristic fire behaviour in accordance with section 5.2.1 - 5.2.3 of DIN EN 13501-2: 2010-2.

2.2 Structural design of the wall construction

Table 1 List of structural details of the tested wall construction

Position	Material/ dimensions	Remark(s)
Supporting structure:	MHM wall element of soft wood Board width $b \geq 180$ mm Board thickness $d_e \geq 23$ mm Element thickness $d \geq 160$ mm	Element connection: At least 2 aluminium ribbed nails at each board intersection. Boards rough sawn in longitudinal direction, on one side with grooves to a depth of 3 mm. The MHM wall was smoothed on one side. The opposite side is rough sawn.
Lining Inner side of wall (side facing fire)	Plasterboard fire bats (PBF bats) $d \geq 15.0$ mm Max. board size: $b \times h \leq 1250$ mm x 2000 mm Joints stopped with Knauf Uniflot. Cross joints are allowed.	Fasteners: Senco N21 clips $\geq 54 \times 12.8$ mm Gap A ≤ 70 mm Gap between rows ≤ 625 mm
Lining Outer side of wall (side facing away from the fire)	Gypsum plasterboards (GP boards) $d \geq 9.5$ mm Max. board size: $b \times h \leq 1250$ mm x 2000 mm Joints stopped with Knauf Uniflot. Cross joints are allowed.	Fasteners: Senco N21 clips $\geq 54 \times 12.8$ mm Gap A ≤ 70 mm Gap between rows ≤ 625 mm



Details of the installation of the electrical installations box

Electrical installation boxes may be installed in the wall construction on the side facing the fire in the following variants.		
Cavity wall box	PVC electrical devices box ≤ Ø 68 mm Depth t ≤ 47 mm	Single coat of paint with DBU dispersion fire protection coating (ETA 13/0165) in box bore. Application amount: ≥ 1kg/m ²
Kaiser fire protection box	HWD 90 ≤ Ø 74 mm Depth t ≤ 44 mm	Approval by construction supervision authorities Z-19.21-1788

The height of the wall construction may not exceed 3,200 mm.

The load on the wall construction is limited to 35 kN/m.

Further structural details as well as the materials used and their building material characteristic values can be found in the test report PB 3.2/14-013-1 from 16.10.2014 of MFPA Leipzig GmbH.

3 Test reports and test results supporting this classification

3.1 Test reports

Table 2 *Compilation of test reports*

Organisation that performed the test	Applicant	Number of the test report	Test standard
MFPA Leipzig GmbH Hans-Weigel-Str. 2 b 04319 Leipzig	MHM Entwicklungs GmbH	PB 3.2/14-013-1 from 16.10.2014	DIN EN 1365-1: 2013-08, in conjunction with DIN EN 1363-1: 2012-10



3.2 Test results

Table 3 *Compilation of the test results*

Test method	Parameter	Test results
DIN EN 1365-1: 2013-08 in conjunction with DIN EN 1363-1: 2012-10	Strength (R)	
	Vertical compression $C = h/100$ [mm]	Limit not reached
	Speed of vertical compression $dC/dt = 3 h/1000$ [mm/min]	Limit not reached
	Integrity (E)	
	Combustion of the cotton ball	no combustion
	Appearance of gaps	no gaps
	Appearance of flames on the opposite side	no sustained appearance of flames
	Thermal insulation (I) – Rise in temperature on the side to which no flames are applied above the initial temperature after the 90th minute of test	
	Mean value > 140 K	2 K
	max. single value > 180 K	4 K

4 Classification and direct field of application

4.1 Reference for classification

This classification was carried out in accordance with DIN EN 13501-2: 2010-02, section 7.

4.2 Classification

This classification has been carried out in compliance with section 7.3.2 of DIN EN 13501-2: 2010-02.

The load-bearing, space-enclosing, thermally-insulating MHM wall element according to section 2.2 has been classified on the basis of the following combinations of performance parameters and classes. Other classifications are not allowed.

R	E	I	W	-	t	-	M	P	C	IncSlow	sn	ef	r
R	E	I	-	-	90	-	-	-	-	-	-	-	-

Fire protection effect: REI-90



4.3 Direct field of application

The results of the fire test are directly applicable to similar designs in which one or several of the changes listed below have been carried out and for which the design continues to meet the requirements of the corresponding design standard in terms of its rigidity and strength. Further changes are not allowed.


- Reduction of the height of the wall,
- Increase in the width of the wall,
- Increase in the thickness of the wall,
- Increase in the thickness of individual components (corresponding materials),
- Reduction of the length of boards and panels, though not the thickness,
- Reduction of the gaps between fastenings,
- Increase in the number of horizontal joints,
- Reduction of the applied load.
- Electrical installation boxes in accordance with section 2.2 may be installed in the room side of the wall.

5 Restrictions


The classification document is not a type approval or certification of the product. It does not replace any building authority certificate that may be necessary according to German building laws (state building code).

This classification report is valid for an unlimited period. It is the responsibility of the certification body to check whether the relevant test and classification standards are valid and/or that no significant changes have been made that may have an effect on the safety level.

Leipzig, 04 December 2014



Dipl.-Ing. S. Hauswaldt
Head of Business Division



Dipl.-Ing. H. Fischkandl
Head of Laboratory



Dipl.-Wirtsch.-Ing. S. Kramer
Testing Engineer